

SPECIFICATIONS

TrafficGuard®, Inc. Deter-a-Post Removable Bollard Specification (4536 PL, 4536 P)

PART 1 GENERAL

1.1 SECTION INCLUDES

1.1.1 Removable bollards and ground sleeves

1.2 PART SPECIFICATIONS

1.2.1 High-Density Polyethylene (HDPE) – bollard post

1.2.2 ASTM A513 Type 5 – bollard ground sleeve & filler piece

1.2.3 8-18 Stainless Steel – ¾” x 6.5” lock pin

1.3 PERFORMANCE REQUIREMENTS

1.3.1 HDPE Bollard post will remove from ground sleeve to provide a flush surface when the post is replaced by the galvanized filler piece.

1.3.2 Unlock and remove padlock from locking pin to enable bollard removal. Pull bollard pin out and push pin horizontally through slot in HDPE post. Once complete, bollard post can be fully removed.

1.4 SUBMITTALS

1.4.1 Submittals document can be found at www.trafficguard.net under “document library” or enclosed with bollard purchase. Follow manufacturer’s specifications and installation instructions as required.

1.5 QUALITY

1.5.1 Bollard post, ground sleeve and filler piece must be supplied by TrafficGuard®. to provide consistent quality in appearance and performance.

1.6 DELIVERY, STORAGE AND HANDLING

1.6.1 Inspect materials upon receipt ensure that the correct materials have been received and that they are in good condition.

1.6.2 If not installing immediately, store units to avoid damage from other construction activities and elements.

PART 2 PRODUCTS

2.1 MANUFACTURERS

2.1.1 TrafficGuard®, Inc., P.O. Box 201, Geneva, IL 60134, Tel 877-727-7347, Fax 800-814-7194, Website: <http://www.trafficguard.net>

2.1.2 The TrafficGuard®, Inc. Deter-a-Post is available in locking & non-locking models. The architect should specify the following models:

4536 PL – 4.5” OD, Removable / Locking, HDPE Deter-a-Post

4536 P – 4.5” OD, Removable / Non-Locking, HDPE Deter-a-Post

2.2 MATERIALS

2.2.1 Plastic Tube: High-Density Polyethylene

2.2.2 Steel Tube: ASTM A513, Type 1

2.2.3 Steel Pins: 3/4” x 6.5”, 8-18 stainless steel

2.3 FABRICATION

2.3.1 After fabrication all ground sleeve and filler piece units are Hot-Dipped Galvanized

PART 3 EXECUTION

3.1 INSTALLATION

3.1.1 Comply with manufacturer provided instructions and drawings.

3.1.2 Ground sleeves should be installed with the top of the sleeve set flush with the finished surface.

3.1.3 Ensure that a minimum of a 3” gravel base is set prior to installation to ensure drainage of the ground sleeve unit, per installation details.

3.1.4 Bollard should not be inserted into the ground sleeve until it is leveled and fully cured. Attach bollard per manufacturer instructions.

3.2 SITE STORAGE AND PROTECTION

3.2.1 Upon receipt of bollard unit(s) all materials should be thoroughly inspected to ensure that all parts have been received in good condition.

3.2.2 Store units in a dry location away from possible damage until the time of installation.